

Technical drawing of the ECH 1000 device, showing front and side views with dimensions and labels.

Dimensions:

- Height: 350
- Width: 215
- Depth: 120

Labels:

- CHARGING STOP PUSH-BUTTON
- SOCKET OUTLET TYPE II
- TYPE 2

The image is a detailed architectural site plan for a facility, likely a parking or service area. It is divided into several distinct zones:

- FILARE ALBERATO - AREA VERDE:** The top section, featuring a row of trees and a green boundary.
- AREA LIBERA:** A large, open rectangular area in the upper center.
- PORTICO PEDONALE:** A central walkway area with a grid of numbered sections (1-19).
- RAMPA MANOVRA E USCITA:** A ramp area on the right side, labeled "RAMPA MANOVRA E USCITA".
- ZONA BAIE DI SCARICO:** A large area on the right, labeled "ZONA BAIE DI SCARICO", containing various infrastructure elements.

The plan includes numerous technical details and labels:

- Water Supply:** Numerous points labeled "n.1 tuba", "n.2 tuba", "n.3 tuba", and "n.4 tuba" with diameters (e.g., #110mm, #160mm).
- Electrical Infrastructure:** Labels for "CABINETTO", "PANNELLO", "CABINATO", and "POMPA ACQUE PIOVANE AUTORMESSA".
- Infrastructure:** "POMPA SCARICO", "POMPA ACQUE PIOVANE IRRIGAZIONE", and "POMPA ACQUE PIOVANE AUTORMESSA".
- Other Features:** "UBICAZIONE NUOVA COLONNINA RICARICA ELETTRICA AUTOVEICOLI (vedere particolare)" with a red arrow pointing to a specific location. "STOP" signs are marked at various points.

The plan is divided into numbered sections (1-19) and includes a "STOP" sign. The overall layout is organized into a grid system, with various infrastructure elements and water supply points distributed throughout the zones.

MARCA: SCAME
SIEIE: LIBERA
MODELLO: 204.WB11RS-T232EV
CARATTERISTICHE: 1 PRESA TIPO 2 32A 230V ac, 7,4kW CON BLOCCO SPINA.

CON IL COLORE "GRIGIO" SONO INDICATE LE APPARECCHIATURE
ELETTRICHE NON OGGETTO DI INTERVENTO



Progettazione impianti tecnologici civili e industriali - Prevenzione incendi

37036 San Martino Buon Albergo (VR) - via Archimede, 10 - piano secondo, interno 13
telefono: 045 8781131 e-mail: elektro@piramide-engineering.com - termo@piramide-engineering.com telefax: 045 8797494

committente:	SUPERMERCATI TOSANO CEREAL s.r.l. 37053 Cerea (VR) - via Palesella, 1
--------------	--

intervento:	Progetto per l'esecuzione, in conformità alle Leggi e Normative vigenti, degli impianti elettrici a servizio del nuovo magazzino e dell'ampliamento autorimessa di una grande struttura di vendita sita in 36073 Cornedo Vicentino (VI) - via Pigafetta, 42
-------------	---

elaborato:	Pianta ubicazione nuova colonnina ricarica elettrica degli autoveicoli
------------	--

commessa: 009-19	file: 009-19-E-PL_colonna	data: 10.2020	disegnatore: per. ind. Ivan Giona
tavola: 01C	foglio: 01/01	scala: 1:400	progettista: per. ind. Andrea Toni

aggiornamenti:	data:

installatore:	progettista: per. ind. Andrea Toni
---------------	---------------------------------------

direttore dei lavori: _____ timbro e firma progettista: _____

note:

timbro e firma progettista: